



CERTIFIKAT O TIPSKEM PRESKUSU

TYPE EXAMINATION CERTIFICATE



STISLJIV CEVNI SISTEM ZA PLINSKE INSTALACIJE

PRESSED PIPE FITTINGS FOR GAS INSTALATIONS

št. certifikata: 8715-2/14

(Certificate no)

velja do: 01. 08. 2017

(Valid until)

Naročnik/dobavitelj :
(Customer/supplier)

Fra.Bo S.p.A.
Via Cadorna 30 – 25027 Quinzano d'Oglio (BS) - Italia

Podatki o izdelku/sistemu:
(Product description)

FRABOPRESS GAS

FRABOPRESS GAS BIG SIZE

- zunanji premer cevi:
(external pipe diameters)

12 ; 15 ; 18 ; 22 ; 28 ; 35 ; 42 ; 54 mm

76,1 ; 88,9 ; 108 mm

- material:
(fitting material)

copper CW024A, red brass

copper CW024A, red brass

- tesnilo (O-ring):
(design temperature)

HNBR - yellow

HNBR - yellow

- maksimalni pogoji obratovanja: Tlak in temperatura po tehničnih podatkih proizvajalca.
(Maximal operating conditions) (Pressure and temperature after the manufacturer's technical data.)

Preskušeni vzorci ustrezajo zahtevam standarda(ov) ali normativnega(ih) dokumenta(ov):
(The samples tested fulfill the requirements of the following standard(s) or regulation(s))

- DVGW-G 5614 (P) (Dezember 2013): Unlösbare Rohrverbindungen für metallene Gasleitungen, Pressverbinder"
- DVGW GW 392: Nahtlosgezogene Rohre aus Kupfer für Gas und Trinkwasser

Certifikat je izdan na osnovi poročila o preizkusu: 45138/14 (E), Instituta za varilstvo d.o.o., z dne 04.09.2014.
(The certificate based on Test report no.: 45138/14 (E) of Welding Institute, of 4th September 2014.)

Kraj in datum: Ljubljana, 01.09.2014
(Place and date)

Direktor:
(Director)

Dr.-Ing. Miro Uran, univ. dipl. inž.



INSTITUT ZA VARILSTVO
Welding Institute