



SWEDISH TYPE APPROVAL 1101

WITH DECISION ON PRODUCTION CONTROL

KEYWORD: Tap water

Holder: FRABO S.p.A

Via Cadorna 30, 26020 Quinzano d'Oglio, Italien

Tel: +39 030 9925711

Fax: +39 030 9924127

Webb: <http://www.frabo.com>

Product name: Frabopress H2O Securfrabo

Press fitting of copper for copper pipe installations. The product is pressed with V-profiled pressing tools. Press fitting has leakage indication (unpressed) and is approved for dimensions Ø 12, 15, 18, 22, 28, 35, 42 and 54 mm

Intended use

Press fitting of copper intended for distribution of hot and cold tap water alt heating within a property where the highest operating pressure does not exceed 1.0 MPa and where the water temperature does not instantaneously exceed 95°C or continuously does not exceed 70°C.

Approval

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Building products with assessed properties	1:4
Installations for tap water	6:62*
Design	6:625

* Complies with requirements in BFS 2014: 3

For the intended use the products meets the following requirements of PBL, regulations governing the technical properties of materials, products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

3. Protection with regard to hygiene, health and environment
4. Safety in use

Appendix 1: Associated documents	22/09/2017
Appendix 2: Product marking	22/09/2017
Appendix 3: Control	22/09/2017
Appendix 4: Basis for approval	22/09/2017

Kiwa Sverige AB
Campus Gräsvik 1
SE-371 75 Karlskrona

Tel +46 (0)455-30 56 00
Fax +46 (0)455-104 36
bygg@kiwa.se
www.kiwa.se




Date of decision: 22/09/2017


Ref. no: 854/17

Valid until: 21/09/2022

Previous ref. no.: 560/12

Kiwa Sverige AB


Magnus Jerlmark
Technical manager


Deo Yamabo
Project leader