



CERTIFIKAT O TIPSKEM PRESKUSU

TYPE EXAMINATION CERTIFICATE



STISLJIV CEVNI SISTEM ZA PLINSKE INSTALACIJE

PRESSED PIPE FITTINGS FOR GAS INSTALATIONS

št. certifikata: 8715-4/14
(Certificate no)

velja do: 01. 08. 2017
(Valid until)

Naročnik/dobavitelj :
(Customer/supplier)

Fra.Bo S.p.A.
Via Cadorna 30 – 25027 Quinzano d'Oglio (BS) - Italia

Podatki o izdelku/sistemu:
(Product description)

FRABOPRESS 316 GAS

FRABOPRESS 316 G BIG SIZE

- zunanji premer cevi:
(external pipe diameters)

12 ; 15 ; 18 ; 22 ; 28 ; 35 ; 42 ; 54 mm

76,1 ; 88,9 ; 108 mm

- material:
(fitting material)

X2 Cr Ni Mo 17 12 2 (W.Nr.: 1.4404)

X2 Cr Ni Mo 17 12 2 (W.Nr.: 1.4404)

- tesnilo (O-ring):
(tight material)

HNBR - yellow

HNBR - yellow

- maksimalni pogoji obratovanja: Tlak in temperatura po tehničnih podatkih proizvajalca.
(Maximal operating conditions) (Pressure and temperature after the manufacturer's technical data.)

Preskušeni vzorci ustrezajo zahtevam standarda(ov) ali normativnega(ih) dokumenta(ov):
(The samples tested fulfill the requirements of the following standard(s) or regulation(s))

DVGW – G 5614 (P) (Dezember 2013): Unlösbar Rohrverbindungen für metallene Gasleitungen, Pressverbinder

Certifikat je izdan na osnovi poročila o preizkusu: 45138/14 (E), Instituta za varilstvo z dne 04.09.2014.
(The certificate based on Test report no.: 45138/14 (E) of Welding Institute, of 4th September 2014.)

Kraj in datum: Ljubljana, 01.09.2014
(Place and date)

Direktor:
(Director)

Dr.-Ing. Miro Uran, univ. dipl. inž.



INSTITUT ZA VARILSTVO
Welding Institute