



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DV-8535CQ0026

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	FRA.BO S.p.A. Via Cadorna, 30, I-25027 Quinzano d'Oglio (BS)
Distributor <i>Vertreiber</i>	FRA.BO S.p.A. Via Cadorna, 30, I-25027 Quinzano d'Oglio (BS)
Product Category <i>Produktart</i>	installation systems and system joints: pressfitting joint for metallic gas and water pipes (8535)
Product Description <i>Produktbezeichnung</i>	Pressfitting joint made of red brass or copper, type M-MM, for pipes made of copper according to DVGW GW 392 (hard and semi hard), unpressed leaky according to DVGW W 534 and DVGW G 5614
Model <i>Modell</i>	FRABOPRESS SECURFRABO
Test Reports <i>Prüfberichte</i>	type testing: VR 001/15 from 21.01.2016 (TZW) type testing: B 15/10/2034 from 26.10.2015 (DBI) hygienic test: 0341LP/2015 from 03.07.2015 (IIP)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW G 5614 (01.12.2013) D.M. 174 (06.04.2004)

70226 04-A-DE

Date of Expiry / File No. 21.01.2021 / 15-0097-WNE
Ablaufdatum / Aktenzeichen

12.02.2016 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
FRABOPRESS SECURFRABO	nominal diameter: DN 12 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 15 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 18 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 22 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 28 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 35 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 42 mm	
FRABOPRESS SECURFRABO	nominal diameter: DN 54 mm	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5112BN0030	Sealing material made of elastomers for HN 707/HN707 gas appliances		Lopigom S.r.l.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Scope gas installation

nominal pressure rate gas: PN 5

ambient temperature range: -20...+70 °C

The requirements for the operating temperature for - 20°C are fulfilled also for - 30°C.

The requirements for the higher thermal loading (HTB) for gas are met up to the nominal pressure rating PN 1 (GT-PN 1).