



CERTIFIKAT O TIPSKEM PRESKUSU

TYPE EXAMINATION CERTIFICATE



STISLJIV CEVNI SISTEM ZA OGREVALNE IN SANITARNE INSTALACIJE

PRESSED PIPE FITTINGS FOR HEATING AND SANITARY INSTALATIONS

št. certifikata: 10108-5/17

(Certificate no)

velja do: 01. 10. 2020

(Valid until)

Naročnik/dobavitelj :
(Customer/supplier)

Fra.Bo S.p.A.
Via Cadorna 30 – 25027 Quinzano d'Oglio (BS) - Italia

Podatki o izdelku/sistemu:
(Product description)

FRABOPRESS C-STEEL SECURFRABO

FRABOPRESS C-STEEL BIG SIZE

- zunanji premer cevi:
(external pipe diameters)

15 ; 18 ; 22 ; 28 ; 35 ; 42 ; 54 mm

76,1 ; 88,9 ; 108 mm

- material:
(fitting material)

W.Nr.: 1.0034

W.Nr.: 1.0034

- tesnilo (O-ring):
(tight material)

EPDM - black ; FKM - green

EPDM - black

- maksimalni pogoji obratovanja: Tlak in temperatura po tehničnih podatkih proizvajalca.
(Maximal operating conditions) (Pressure and temperature after the manufacturer's technical data.)

Preskušeni vzorci ustrezajo zahtevam standarda(ov) ali normativnega(ih) dokumenta(ov):
(The samples tested fulfill the requirements of the following standard(s) or regulation(s))

DVGW W 534 (2015-07): Rohrverbinder und Rohrverbindungen

Certifikat je izdan na osnovi poročila o preizkusu: 68043/17 (E), Instituta za varilstvo d.o.o., z dne 26.10.2017.
(The certificate based on Test report no.: 68043/17 (E) of Welding Institute, of 26th October 2017.)

Kraj in datum: Ljubljana, 26.10.2017
(Place and date)

Direktor:
(Director)

Dr.-Ing. Miro Uran, univ. dipl. inž.

